


# GT2 Grease Interceptor passive/biological specification

## Main Tank Dimensions




## Minimum Footprint Dimensions When Installed

**NOTES:**

Allow for the minimum clearances shown including plumbing bend attachments (excluded)

Allow additional 150mm length clearance for outlet sampling port where applicable

Ensure access to strainer basket, located at inlet side of unit



## TECHNICAL DATA

Weight	22 KG
Tank Material	stainless steel, 1.2mm, X6 CrNi1810
Meals per Day Rating	130
Maximum sink capacity served	124 litres
Maximum Flow Rate served	1.25 litres per second
Grease Retention Capacity	30.8 kg
Solid Strainer Capacity	4.4 litres
Strainer Basket maintenance	Empty 1-2 times daily
Tank Pump out Frequency - passive unit	1 x 15 days
Tank Pump out Frequency - biological unit	1 x 60 days
Fluid dosage rate - biological unit	7.8 litres per month

Sizing data is calculated using ASME 112.14.3 & PDI G101 standards